

Addendum No. 1
For
Fort Avenue Sewer Replacement
Town of Blackstone, Virginia
May 5, 2026

You are hereby directed at making the following changes to the contract documents for the above-mentioned project:

Contents

- Remove and destroy Contents Page i and replace with Contents page i (Addendum No. 1)

Bid

- Remove and destroy Bid Form Pages 1 through 7 in its entirety and replace them with Bid Form 1 through 8 (Addendum No. 1)

Specifications

- Section 012200-Unit Prices
 - Revise 3.1 B 13 to read as follows:
“13. Plug and Abandon Existing Manhole: Plug and abandon existing manhole after new sewer installation or the complete manhole removal for sewer line installation as designated in drawings and in accordance specification. Unit: each. Measurement: per 5-foot depth interval derived from manhole tops and its lowest invert of manhole abandoned. (Addendum #1) “
 - Add Paragraph 3.1 B 16 & 17 to read as follows:
“16. Doghouse Manhole: Furnish and install new doghouse manhole as specified in drawings including excavation, dewatering, bedding, 48-inch diameter manhole riser with cut out opening, slab for riser to seal to, riser sections, cone, grade rings, steps, pipe openings and boots, removal of section of pipe, bench and channel formation, standard ring and cover, backfill, restoration, etc., complete and ready for use. Unit: each. Measurement: per 5-foot depth intervals derived from manhole top and its lowest invert. (Addendum #1) “

“17. Connection to Existing Sewer Line: Furnish and install a Hulk Connection for the connecting of new sewer line to existing sewer line and miscellaneous items as required for complete tie-in connection and ready for sewer line extension. Unit: each. Measurement: per Hulk Connection installed. (Addendum #1) “

Drawings

- **Sheet C-1-Plan and Profile**
 - Remove and Destroy Sheet C-1 Plan and Profile and replace with Sheet C-1 Plan and Profile Addendum No. 1. Change reflects relocation Manhole A-3 & A-4.

- **Sheet C-2-Standard Sewer Details**
 - Remove and Destroy Sheet C-2 Standard Sewer Details and replace with Sheet C-1 Plan and Profile Addendum No. 1. Change reflects adding a Doghouse Manhole Detail.

Attachments

- **Pre-Bid Attendance**
- **Pre-Bid Minutes**
- **Bidder's List**